

ALL DCA SERIES COMMERCIAL / INDUSTRIAL DEHUMIDIFIERS SPECIFICATION DATA

A. GENERAL INFORMATION

The DCA dehumidifier is an industrial grade, self-contained, closed loop heat recovery system. This piece of equipment shall include at least the following components; freon compressor, dehumidifier coil (evaporator), air reheat coil (condenser), centrifugal air moving blower, blower motor, various refrigeration components including copper piping, valves and all electrical controls and devices. The configuration of the dehumidifier will be horizontal in design intended for swimming pool applications and all application where the control of humidity is critical.

B. OPERATIONAL MODES

1. Dehumidification and Room Air Heating
2. Dehumidification and Room Cooling, Remote Outdoor Condenser (optional)
3. Dehumidification and Pool Water Heating (optional)
Dehumidifier shall be manufactured to include all equipment needed to readily add on an air cooled remote condenser, to include all refrigeration parts for full flooding operation and all electrical apparatus to accommodate remote condenser.

C. CABINET CONSTRUCTION

The base panel shall be 11-gauge galvanized steel with 11 gauge welded supports on the bottom side for maximum rigidity. The frame panels, removable access doors and top panels shall be 16 or 20 gauge galvanized steel. Removable access doors will provide fingertip access to all major and minor replaceable components of the unit. The electrical compartment shall be separated from the mechanical area with access with its own door from the outside of the cabinet.

D. PAINT AND CABINET FINISH

All metal parts shall be galvanized coated steel in its raw state. All metal cabinet parts shall be painted by the following process:

1. Metal pretreatment using phosphate cleaning and rinsing.
2. Moisture removal via forced warm air oven
3. Primer application.
4. Primer curing via high temperature oven
5. Finish coat applied using a high solids liquid or powder coat material

6. Finish coat cured using a high temperature curing oven

D. DEHUMIDIFICATION COIL (EVAPORATOR)

Coil tubes shall be made from 3/8" or 1/2" OD seamless drawn, rifle tube design, copper and be hydraulically extruded into the fins to form a permanent bond, metal to metal, for maximum heat transfer and overall stability. The fins shall be constructed from die-formed flat tempered stock for easy cleaning. Accurate fin spacing of 8 fins per inch and extruded fin collars providing maximum heat transfer and efficiency. All headers, manifolds and connecting copper tubing to be made from heavy wall seamless tubing. Final testing shall consist of leak testing with 420 psig nitrogen gas and sealed after testing to avoid contamination. Coil casing shall be at least 18 gauge galvanized steel.

E. AIR REHEAT COIL (CONDENSER)

This coil shall be constructed with seamless drawn, rifle tube design, copper tubing, hydraulically expanded into the fin collars to form a metal bond for maximum heat transfer and overall stability. Coil fins shall be tempered aluminum with extruded collars and accurately spaced at 12 fins per inch. All headers shall be constructed from heavy wall seamless copper tubing. Coil casing shall be made from at least 18 gauge galvanized steel. Coil testing shall be leak tested with at least 420 psig nitrogen gas and then sealed to avoid contamination.

F. Pool water heat EXCHANGER (optional)

This pool water heating vessel shall be coaxial in design with cupro-nickel inner tube and corrosion resistant steel outer shell. It shall be sized for use as a full system capacity condenser.

G. EVAPORATOR CONTROL

A damper assembly, located above the evaporator coil, can be controlled either with a manual or an electrically controlled device to maintain optimum coil efficiency under varying load conditions.

H. COMPRESSOR

The freon compressor shall be a scroll design which is heavy-duty and fully hermetic. Also included is a crankcase heater to protect against liquid slugging and a hard start system on all single phase applications. The compressor shall be protected with both high and low pressure safety switches and internally protected from both overheating and over pressure situations. The compressor shall be vibration isolated externally and internally.

I. LOW AMBIENT CONTROL

The low ambient control will control discharge pressure regardless of ambient temperature. A hot gas bypass valve shall prevent evaporator coil freeze ups and the need for defrost timers. This control shall also be externally adjustable by the technician to suit specific installations.

J. FREON RECEIVER VESSEL

This receiver shall be safety laboratory listed and meet ASME standards for 400psig maximum working pressure. Receivers shall also be fitted with pressure safety relief valves listed by safety laboratories for such use. This receiver shall also be equipped with roto-lock refrigeration valves to provide for freon pump down for easy replacement of components.

K. CONDENSATE DRAIN PAN

The drain pan shall be constructed from 20-gauge or heavier stainless steel with silver soldered seams. This pan shall be securely attached with clips, but easily removed for cleaning.

L. ELECTRICAL CONTROL PANEL

The electrical control panel with hinged door and quarter turn latch shall be readily accessible from the front of the unit. The electrical controls shall include IEC starters for compressor (three phase only) and blower motor and interlock relay. A low voltage power supply to supply 24 volt control power with integral circuit breaker or fused protection. Clearly labeled high and low voltage terminal strips, potential relay, start and run capacitors, automatic reset of low pressure cut-out and a short cycling timer to prevent against rapid cycling of compressor. The following indicating lights will be prominently displayed outside the cabinet 1. System 2. Blower 3. Compressor

M. REFRIGERATION CIRCUITRY

All refrigeration copper tubing and components to be coated with a clear polyurethane coating to prevent early deterioration and degradation. The entire refrigeration system to be pumped down to no less than 500 microns and charged with the appropriate amount of HCFC 22.

N. INSULATION

The sound and thermal insulation shall be applied to the bottom, top and all interior sides of the cabinet. It shall be a fiberglass, bonded with a thermosetting resin and flame-attenuated. It shall resist fire up to 250F and withstand air over velocities to at least 5000 feet per minute. It shall also possess the following minimum standards. Flame spread - 25 Smoke developed - 15 Fuel for fire contribution - 0 NFPA 90 and 90B/ASTM-C 1071, federal Specification - HH-1-545B/R-21, ULCCAN4-S102

O. AIR BLOWER ASSEMBLY

The blower shall be a double inlet, forward curve, centrifugal, low RPM type blower that is dynamically and statically factory balanced. Permanently lubricated ball bearings to provide at least 200,000 hours of average life. The blower shall be vibration isolated when mounted to the cabinet floor. The Blower Motor Shall Not Be Attached Mechanically To The Blower In Any Way, other than the drive belt.

P. BLOWER MOTOR

The blower motor shall be a totally enclosed fan cooled design (TEFC) with class B insulation, continuous duty, 40 degree C ambient with overload protection. It shall have permanently lubricated ball bearings, a key slotted shaft with rigid or resilient mount. It shall carry a Type U thermally protected automatic resetting high temperature control, SF 1.35. The motor shall carry a UL and CSA Listing. Blower motor shall be base mounted and not attached to blower mechanically.

Q. BLOWER DRIVE COMPONENTS

The motor pulley and blower pulley shall be machined cast iron in construction. The motor pulley shall be a variable pitch type that is field adjustable to vary CFM and external static pressure. The pulleys shall be single V-Belt up to and including 5HP.

R. RETURN AIR FILTERS

Filters shall be of a disposable type with a UL flammability class rating of 2,3777-AUL. Permanent aluminum cleanable filters are an option to any system.

S. WARRANTY

This unit shall be comprised of the finest components available, which are readily available either as off the shelf replacements or replacements readily available from factory. See limited product warranty.

T. APPROVAL AND AGENCY LISTINGS

This unit shall be manufactured, tested and listed to meet the most rigid standards of  Laboratories.

U. MANUFACTURER OF EQUIPMENT

This unit shall be manufactured by DEHUMIDIFIER CORPORATION OF AMERICA (DCA), Cedarburg, WI. pressure situations. The compressor shall be vibration isolated externally and internally.