



"Mobile Cooling Redefined"

**Cleva Technologies**  
 1951 NW 19th Street  
 Boca Raton, FL 33431  
 www.VectorClimate.com  
 info@vectorclimate.com

**Manufacturer Recommended Care & Maintenance Schedule**

**\*\*Perform all care and maintenance procedures with system off and unplugged\*\***

Section	Procedure/Inspection	Daily	Weekly	Monthly
<b>Body</b>	Wipe down with a damp cloth as needed.	X		
	Hose down system to remove any dirt or dust build up.		X	
	Clean the body with a mild soap.			X
	Decalcification on outside surfaces <i>(as needed)</i> <i>Can use household cleaner such as CLR etc...</i>		X	X
<b>Power Cord</b>	Check cord for tears or exposed wires <i>Do not use system if any cord damage is noted</i>	X		
	Check to ensure the cord does not pose a trip hazard	X		
<b>Tank</b>	Completely drain tank and refill tank <i>(after two days of non-use)</i>	X		
	Clean tank when the Red Tank Alert LED is Solid <i>(On control panel)</i>		X	X <i>(or as needed)</i>
<b>Storage</b>	Completely drain water from the tank.	X	X	X
	Wrap power cord	X	X	X
	Remove both fill and drain caps for airflow. (Store in a safe location)		X	X